



NOTES

1. DO NOT SCALE FROM THIS DRAWING.
2. ALL LEVELS IN METRES UNLESS NOTED OTHERWISE ON DRAWING.
3. ALL DIMENSIONS AND LEVELS TO BE CHECKED ON SITE PRIOR TO UNDERTAKING ANY WORKS, ORDERING MATERIALS OR FABRICATING ANY COMPONENTS
4. THIS DRAWING IS TO BE READ IN CONJUNCTION WITH ALL OTHER RELEVANT ENGINEER'S AND ARCHITECT'S DRAWINGS AND RELEVANT SPECIFICATION CLAUSES.
5. LIGHTING COLUMNS AND BRACKETS SHALL COMPLY WITH MCHW1 CL. 1302.
6. LIGHTING COLUMNS AND BRACKETS SHALL BE PROTECTED AGAINST CORROSION TO THE REQUIREMENTS OF MCHW1 CL. 1909 FOR GALVANISED COLUMNS AND/OR CL. 1921 FOR PAINTED COLUMNS. ABACUS TB061 OR EQUAL APPROVED INSTALLED STRICTLY IN ACCORDANCE WITH MANUFACTURERS INSTRUCTIONS
7. BACKFILLING FOUNDATIONS SHALL COMPLY WITH MCHW1 CL. 1305.
8. CABLE ENTRY HOLE SHALL BE SMOOTH AND HAVE A MINIMUM WIDTH OF 50mm.
9. A DUCT EQUAL IN SIZE TO THE WIDTH OF THE CABLE ENTRY HOLE SHALL BE MADE THROUGH THE CONCRETE FILLING TO MCHW1 CL. 1305.4.
10. LANTERN TO BE IP66 RATED 2 MODULE LED WITH DIE-CAST/PROFILED ALUMINIUM HOUSING. ABACUS CHALLENGER 1 4000K LED. REF. AL63/05/S/R OR EQUAL APPROVED. TO BE INSTALLED STRICTLY IN ACCORDANCE WITH MANUFACTURERS INSTRUCTIONS. TILT=0, CANT=0, CRI Ra70

S1	P01	11.07.22	FIRST ISSUE				
SUITABILITY	REV	DATE	DESCRIPTION	Org	Chkd	Apprd	Auth.

DRAWING STATUS:

PROJECT TITLE:

HUWS GRAY, BRYN CEGIN INDUSTRIAL ESTATE, LLANDYGAI

DRAWING TITLE:

PROPOSED SECURITY LIGHTING

DRAWING No:

PROJECT	ORIGINATOR	VOL.	LOC.	TYPE	ROLE
017321	CCE	ZZ	ZZ	40:40:01	C
15	0005	S1	P01		
CLASSIFICATION		No.	SUITABILITY	REVISION	

ORIGINATOR:	DATE:	SCALE:	ORIGINAL SIZE:
D.P.	19.07.2022	1:1250	A3



Address: CADARN Consulting Engineers Ltd,
Suite B,
Anglesey Business Centre,
Bryn Cefni,
Llangefni,
LL77 7XA
E-mail: admin@cadarnconsulting.co.uk
Tel: 01407 730912